



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0956

Homer Central Schools

Project Name: Drinking Water Lead

Scott Cavellier  
P.O. Box 500  
Homer, NY 13077-0500

Project / PO Number: Elementary School  
Received: 04/13/2017  
Reported: 04/20/2017

Analytical Testing Parameters

<b>Client Sample ID:</b>	Room 105 BR Sink 10 (Single Handle Faucet)	<b>Collected By:</b>	KN-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	04/13/2017 5:45
<b>Lab Sample ID:</b>	J7D0956-01		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00936	0.000500	mg/L		04/18/17 1153	04/18/17 1845	NY

<b>Client Sample ID:</b>	Kitchen 116 Dishwasher Sink 42 (30 Second Draw)	<b>Collected By:</b>	KN-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	04/13/2017 5:49
<b>Lab Sample ID:</b>	J7D0956-02		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00951	0.000500	mg/L		04/18/17 1153	04/18/17 1845	NY

<b>Client Sample ID:</b>	Kitchen 116 Hand Sink 45	<b>Collected By:</b>	KN-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	04/13/2017 5:51
<b>Lab Sample ID:</b>	J7D0956-03		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00557	0.000500	mg/L		04/18/17 1233	04/18/17 1845	NY

<b>Client Sample ID:</b>	Main Hall Girls BR Sink 74	<b>Collected By:</b>	KN-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	04/13/2017 5:54
<b>Lab Sample ID:</b>	J7D0956-04		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.0246	0.000500	mg/L		04/18/17 1331	04/18/17 1845	NY

<b>Client Sample ID:</b>	Main Hall Boys BR Sink 75	<b>Collected By:</b>	KN-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	04/13/2017 5:54
<b>Lab Sample ID:</b>	J7D0956-05		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.0806	0.000500	mg/L		04/18/17 1046	04/18/17 1845	NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0956

**Laboratory**

NY: Microbac Laboratories, Inc., New York Division

---

**Definitions**

AL: US EPA Action Level

RL: Reporting Limit

---

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Alayna Dawson".

Alayna Dawson  
Administrative Assistant  
alayna.dawson@microbac.com  
04/20/2017 10:43

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

