



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0954

Homer Central Schools

Project Name: Drinking Water Lead

Scott Cavellier
P.O. Box 500
Homer, NY 13077-0500

Project / PO Number: Junior High School
Received: 04/13/2017
Reported: 04/20/2017

Analytical Testing Parameters

Client Sample ID:	Science Hall BR Sink 142	Collected By:	KN-Client
Sample Matrix:	Drinking Water	Collection Date:	04/13/2017 7:16
Lab Sample ID:	J7D0954-01		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00395	0.000500	mg/L		04/18/17 1153	04/18/17 1845	NY

Client Sample ID:	Science Hall Fountain 170	Collected By:	KN-Client
Sample Matrix:	Drinking Water	Collection Date:	04/13/2017 7:16
Lab Sample ID:	J7D0954-02		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00308	0.000500	mg/L		04/18/17 1153	04/18/17 1845	NY

Client Sample ID:	Room 160 Sink 203	Collected By:	KN-Client
Sample Matrix:	Drinking Water	Collection Date:	04/13/2017 7:28
Lab Sample ID:	J7D0954-03		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.0147	0.000500	mg/L		04/18/17 1233	04/18/17 1845	NY

Client Sample ID:	Tech Hall Boys BR Sink 205	Collected By:	KN-Client
Sample Matrix:	Drinking Water	Collection Date:	04/13/2017 7:29
Lab Sample ID:	J7D0954-04		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.0128	0.000500	mg/L		04/18/17 1331	04/18/17 1845	NY

Client Sample ID:	Room 177 Sink 230	Collected By:	KN-Client
Sample Matrix:	Drinking Water	Collection Date:	04/13/2017 7:13
Lab Sample ID:	J7D0954-05		

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00782	0.000500	mg/L		04/18/17 1331	04/18/17 1845	NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0954

Client Sample ID: Spec. Ed Boys BR Sink 234	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 04/13/2017 7:15
Lab Sample ID: J7D0954-06	

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00489	0.000500	mg/L		04/18/17 1233	04/18/17 1845	NY

Client Sample ID: Spec. Ed Girls BR Sink 239	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 04/13/2017 7:14
Lab Sample ID: J7D0954-07	

Lead and/or Copper, Total - ICP/MS	Result	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4							
Lead	0.00887	0.000500	mg/L		04/18/17 1153	04/18/17 1845	NY

Laboratory
NY: Microbac Laboratories, Inc., New York Division

Definitions
AL: US EPA Action Level
RL: Reporting Limit

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Alayna Dawson
Administrative Assistant
alayna.dawson@microbac.com
04/20/2017 10:36

3921 Buck Drive
 Cortland NY 13045
 Phone:(607)763-3403 Fax:(607)763-3415
 NY #10795, EPA #NY00835

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #:

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	HOMER CSD					Ice:	YES NO
Address:	80 S. WEST RD					Cooler:	YES NO
Contact:	HOMER, NY 13077					Sample Temp:	—
Phone:	607-749-1234 x 1					Cooler Seal:	YES NO
Project:	JUNIOR HIGH SCH					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	G W
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH:	Yes					Container Material:	
Email Results:	Yes SCAVELLIER@HOMERCENTRAL.ORG					Container Size(In MI):	
Fax Results:	Yes					Preservative:	
Sample Information		Matrix Type		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial				
1 SCIENCE HALL (142) BR SINK	4/13/17	716	KP				
2 SCIENCE HALL (170) FOUNTAIN	4/13/17	716	KP				
3 ROOM 160 (203) SINK	4/13/17	728	KP				
4 TECH HALL BOYS (205) BR SINK	4/13/17	729	KP				
5 ROOM 177 (230) SINK	4/13/17	713	KP				
6 SPEC. ED BOYS (234) BR SINK	4/13/17	715	KP				
7 SPEC. ED GIRLS (239) BR SINK	4/13/17	714	KP				
8							
Sampled:	Kelly Neish	Signature		Date/Time	4/13/17 1123	Comments	
Received:	Danille Gower			Date/Time	4/13/17 123		
Received:							
Received:							
Received:							
Received:							



J7D0954